

### **KIRLOSKAR OIL ENGINES LIMITED**

A Kirloskar Group Company

Туре	SAE
Standby Power (ESP)	/A / kWe 1
Prime Power (PRP)	/A / kWe 12
Phase / Volt	3 Pha

# 50 Hz

Power, Performance, Peace of mind



Note: Above picture shown for illustration purpose only, actual product may be different.



Generating Set Specifications							
Model			138WS50	138W50			
Туре			SAE	Open			
Line Voltage		V	400				
Phase Voltage		V	230				
Power factor			0.8 (lag)				
Fuel tank capacity		L	225 225				
Evel consumption 0/ of	50% load	L/hr	15.5				
Fuel consumption % of 75% load		L/hr	20.7				
	100% load	L/hr	26.8				
Sound level at 7m at 75%	dB(A)	70					

Engine, Alternator and Controller						
	Engine	Alternator	Controller			
Make	Kirloskar	Stamford	Deepsea			
Model	4K1080TA	UCI274V1/E1	DSE6120 MKII			
Туре	Liquid cooled	Brushless	Microprocessor based			

### **Product Benefits**

- High Performance and Reliability
- Low Fuel Consumption
- Extended Service Interval
- Easy Installations
- Low maintenance cost

### **Performance Assurance**

- Total Quality Management System
- Engines & Generating set fully manufactured by us in facilities certified to ISO9001, ISO 14001 & OHSAS 18001
- Generating set complies to ISO 8528
- Engines comply to ISO 3046 & AC Generators comply to BS5000, IEC34

#### Support

Service support in all countries of operation

1. +5% tolerance is applicable as per ISO3046. Fuel consumption based on diesel fuel with a specific gravity of 0.85 and confirming to BS 2869, Class A2.





# **Engine Specifications**

Physical Data		Air System			
Engine rpm	1500	Air filter type	Dry replaceable		
Configuration	Inline	Air volume required for combustion (m <sup>3</sup> /hr)	665		
Cylinders	4	Air volume required for cooling (m <sup>3</sup> /hr)	18000		
Туре	Four stroke	Air volume required by alternator (m <sup>3</sup> /hr)	1850		
Bore x Stroke (mm)	105 x 125	Total fresh air required (m <sup>3</sup> /hr)	20515		
Displacement (L)	4.32				
Cooling	Liquid cooled	Cooling System			
Aspiration	Turbo Charged After cooled	Cooling system capacity (L)	54		
Compression ratio	15.5 : 1		Ethylene glycol based premixed with		
Piston speed (m/s)	6.25	Coolant type	water in ratio 50:50,		
hp Prime @ 1500rpm	156		antifreeze & anti corrosion type		
hp Standby @ 1500rpm	171.6	Radiator fan load (hp) 6.5			

Fuel System		Exhaust System	
Type of fuel filter	Two stage spin on type	Exhaust gas flow rate (kg/hr)	900
Governor type	Electronic	Maximum exhaust gas temperature (°C)	ТВА
Class of governing	ISO 8528-5, Class G2	Max. allowed back pressure (mm of Hg)	50
Recommended Fuel	Class A2, High speed diesel	Flange details for exhaust piping extension (mm)	PCD 190+/-0.5, 8 holes 17.0 +/-0.5

Electrical System		Lubrication System			
Starting arrangement	12V Electric	Type of lube oil filter	Full flow spin on type		
Starter battery rating	120Ah	Oil to be used	SAE 15W40 API:CI4		
Battery charging alternator	Engine mounted 12V	Oil pump type	Through G-rotor gear pump		
Battery charging alternator	35	Lube oil sump capacity (L) refill / first fill	14 / 17		
Battery charger <sup>2</sup>	12V 2A / 5A with float & boost mode	Lube oil consumption	0.3% of fuel consumption		



2. Optional extra accessory.



# **Alternator Specifications**

Alternator Physical Data			Alternator Operating Data			
	Insulation Class	Н	Over speed (RPM)	2250		
Continuous rating	kVA at 0.8 PF	125				
raung	Temperature rise (°C)	125 /40°C	Excitation	Self-excited (brushless)		
Number of b	earings	1	Cooling method	Forced through shaft mounted blower fan		
Pole		4	THD at full linear balanced load AC waveform	Less than 5%		
Leads		6	Efficiency full load (%)	91.7		
Winding pitc	h	2/3	Voltage Regulation (%)	± 1.0		
Ingress Prote	Ingress Protection Rating IP 23		Reactance per unit (Xd)	2.15		
Voltage regulator		AS440	Reactance per unit (X'd)	0.19		
Recommended earthing type		Solid separate for neutral and body	Reactance per unit (X"d)	0.12		

# **Control System Features and safeties**

On display screen		Protections	Warning	Shutdown	Indication	Digital Input
Generator Volts, Amps. Hz	✓	Low oil pressure	No	✓	✓	
Generator kW, kVA, kVAr	✓	High coolant temperature	✓	~	~	
Generator per phase PF	✓	Low fuel level	✓	$\checkmark$	✓	
Generator kWHr meter	✓	Low coolant level	No	~	~	
Earth current (A)	No	Under & over speed	✓	✓	✓	
Grid (Mains) Voltage (L-L)	✓	Low & high battery voltage	✓	No	~	
Battery Voltage (V)	✓	Low charge alternator	✓	No	$\checkmark$	
Engine start attempts	✓	Emergency stop	No	~	~	
Engine Temperature (°C)	✓	Fail to start & fail to stop warning	~	No	~	
Engine speed (RPM)	✓	Auto remote start/stop DI				$\checkmark$
Engine Run Hours (Hours & Min.)	✓	Under & over voltage	✓	$\checkmark$	$\checkmark$	
Lube oil Pressure (kPa, PSI, bar)	✓	Under & over frequency	✓	$\checkmark$	✓	
Fuel level (%)	✓	Over kW or Overcurrent	No	~	~	

Communication ports				
RS485	No			
RS232	No			

✓ Available

No - Not available ---- Not applicable





## **Standard and Optional Features**

### Generating Set (\*applicable only for SAE type)

• • •	Top lifting arrangement* Silencer mounted inside canopy* External fuel filling access* Longer fuel tank breather tube	• • •	Door for radiator access* Coolant drain arrangement Mesh on exhaust tail pipe Fuel transfer pump	• • 0	Stainless steel door hinges* Control panel door stopper* Fuel priming manual pump External standalone fuel tank		
En	gine						
• •	SMF Battery Lube oil drain pump* Dual (electrical + mechanical) fuel gauge	•	Guard for rotating parts Water separator Electronic governor	•	Over-cranking protection Jacket water heater		
Alt	ternator						
0	Alternator space heater	0	Remote voltage adjustment potentiometer	0	PMG		
0	Alternator inlet louver filter	0	Droop current transformer				
Co	ontrols						
٠	Automatic Starting & AMF facility	0	Communication port RS485/RS232	0	Static Battery charger		
0	ATS Panel	0	Synchronization panels	0	Kirloskar remote monitoring (KRM) unit		
0	4 Pole circuit breaker	0	Shut down hooter	0	Dummy Load bank		
• St	Standard Feature Optional Feature						

#### Generating set ratings definitions as per ISO8528:

(De-rating is applicable for climatic conditions other than standard reference conditions of ISO8528-1)

<u>Standby Rating / Emergency Standby power / ESP:</u> These ratings are applicable for supplying electrical power at variable load in the event of a utility power failure. The standby power is maximum power available with no overload permitted on these ratings. The permissible average power output over 24 hours of operation shall not exceed 70% of the ESP. The alternator on this model is peak continuous rated (as defined in ISO 8528-3)

<u>Prime Rating / PRP:</u> These ratings are applicable for supplying continuous electrical power at variable load in lieu of commercial purchased power. There is no limitation to the annual hours of operation and this model can supply 10% overload power for 1 hour in 12 hours. The permissible average power output over 24 hours of operation shall not exceed 70% of the PRP.

**Continuous Rating / COP:** These ratings are applicable for supplying power continuously to a constant load up to the maximum output rating for unlimited hours. No sustained overload capability is available for this rating.





# **Documents & Quality Standards**


### **Documents**


Generating set user manual, engine operation and maintenance manual - in soft form

#### **Quality standards**

ISO 8528, ISO 3046, IS 10002, BS5514, DIN 6271, ISO 9001, ISO 14001

Weight & Dimensions							
Model			138WS50	138W50			
Туре			SAE	Open			
Overall dimensions <sup>3</sup>	Length x Width x Height	cm	327 x 116 x 193	224 x 104 x 164			
Weight⁴	Weight with oil & coolant	kg	2180	1510			





3. Dimensions are for logistics purpose only. Please refer installation / GA drawing for installation.

4. Weight mentioned is for indicative only. Actual weight may vary based on configuration.

### **KIRLOSKAR OIL ENGINES LIMITED**

A Kirloskar Group Company Head Office: Laxmanrao Kirloskar Road, Khadki, Pune 411 003, India. Tel.: +91 20 2581 0341 / 534 Fax: +91 20 2581 3208 Website: www.koel.co.in

#### International business office:

#### **KIRLOSKAR DMCC**

JBC-5, Cluster W, Jumeirah Lake Towers, P. O. Box 37745, Dubai. U.A.E Tel.: +971 4 443 8591 Fax: +971 4 441 4532 Email: <u>enquiry@kirloskar.ae</u> Website: <u>www.kirloskarib.com</u>

### KIRLOSKAR TRADING SA(PTY)

Unit B1, The Stables Business Park, Cnr of Third Avenue & Second Road, Limbro Park, Modderfontein, Johannesburg. Tel.: +27(0) 11 553 6900/6903 Email: kirsons@kirloskar.co.za

#### KIRLOSKAR KENYA LTD.

P.O. Box 60061, Off Dunga Road, Nairobi, Kenya. Tel.: +254 20 653 6632 Fax: +254 20 653 3390 Email: rspatil@kirloskar.co.ke

#### KOEL AMERICAS CORPORATION

33300 Egypt Lane, Suite C300, Magnolia, TEXAS – 77354, United States Tel.: +1 346 248 5777 Email: Vinay.Kulkarni@koelamerica.com

# THE REP. OFFICE OF KIRLOSKAR

Suite 1331A, 13th Floor, Level One Saigon, mPlaza Saigon, No. 39 Le Duan Street, Ben Nghe Ward, District 1, Ho Chi Minh City, Vietnam Tel.: +84 77 9659756 Email: Sanjay.Kunchetti@kirloskar.com

Kirloskar Oil Engines Limited reserved the right to change the design or specifications without notice.